

**TABELA
TEMPERATUR
95/70°C**

**Źródło: dla odbiorców z
CWU**

Opracowana na podstawie Decyzji Nr 4 Ministra Gospodarki Materialowej i Paliwowej z dnia 4 czerwca 1987 r.

tzew	Tz	Tp
12	65,0	60,0
11	65,0	59,4
10	65,0	58,8
9	65,0	58,1
8	65,0	57,5
7	65,0	56,9
6	65,0	56,3
5	65,0	55,6
4	65,0	55,0
3	65,0	54,4
2	65,0	53,8
1	65,0	53,1
0	65,0	52,5
-1	65,0	51,9
-2	66,3	52,6
-3	68,0	53,7
-4	69,7	54,7
-5	71,4	55,7
-6	73,0	56,8
-7	74,7	57,8
-8	76,3	58,8
-9	77,9	59,8
-10	79,5	60,7
-11	81,1	61,7
-12	82,7	62,7
-13	84,2	63,6
-14	85,8	64,5
-15	87,4	65,5
-16	88,9	66,4
-17	90,4	67,3
-18	92,0	68,2
-19	93,5	69,1
-20	95,0	70,0