

Temperatura zewnętrzna	Temperatura zasilania	moc kW	przepływ	T powr.
-18	110,0	17862	255,976	50,0
-17	109,0	17397,59	255,976	50,6
-16	108,0	16915,31	255,976	51,2
-15	107,0	16450,9	255,976	51,7
-14	106,0	15986,49	255,976	52,3
-13	105,0	15754,28	255,976	52,1
-12	104,0	15504,22	255,976	51,9
-11	103,0	14557,53	255,976	54,1
-10	101,0	14093,12	255,976	53,7
-9	99,0	13628,71	255,976	53,2
-8	97,0	13164,29	255,976	52,8
-7	95,0	12682,02	255,976	52,4
-6	93,0	12217,61	255,976	52,0
-5	91,0	11753,2	255,976	51,5
-4	89,0	11020,85	255,976	52,0
-3	87,0	10806,51	255,976	50,7
-2	85,0	10324,24	255,976	50,3
-1	83,0	9877,686	255,976	49,8
0	81,0	9395,412	255,976	49,4
1	80,0	8931	255,976	50,0
2	79,0	8466,588	255,976	50,6
3	77,0	7984,314	255,976	50,2
4	75,0	7519,902	255,976	49,7
5	73,0	7055,49	255,976	49,3
6	72,0	6573,216	255,976	49,9
7	71,0	6108,804	255,976	50,5
8	70,0	5626,53	255,976	51,1
9	70,0	5162,118	255,976	52,7
10	70,0	4697,706	255,976	54,2
11	70,0	4215,432	255,976	55,8
12	70,0	3751,02	255,976	57,4