

TABELA TEMPERATUR 100/70°C (z cwu)

Kotłownia: **Małogoszcz**

tzew	Tz	Tp
12	65,0	59,0
11	65,0	58,3
10	65,0	57,5
9	65,0	56,8
8	65,0	56,0
7	65,0	55,3
6	65,0	54,5
5	65,1	53,9
4	67,6	55,6
3	70,0	57,2
2	72,3	58,8
1	74,7	60,4
0	77,0	62,0
-1	79,3	63,5
-2	81,6	65,1
-3	83,8	66,6
-4	86,1	68,1
-5	88,3	69,5
-6	90,5	71,0
-7	92,7	72,4
-8	94,9	73,9
-9	97,0	75,3
-10	99,2	76,7
-11	100,0	76,8
-12	100,0	76,0
-13	100,0	75,3
-14	100,0	74,5
-15	100,0	73,8
-16	100,0	73,0
-17	100,0	72,3
-18	100,0	71,5
-19	100,0	70,8
-20	100,0	70,0